

Certificate of Suitability

Certificate No.: SAA181176

Certificate Holder: Eguana Technologies Inc.

3-6143 4th Street SE Calgary, AB T2H 2H9

Canada

Class Description: Non-Declared Product Description: AC Battery System

Brand Name: EVOLVE ACB05-LP

Markings: DC: 48Vdc Charge/Discharge 100/125A

AC Input/Output: 230/240V~ 50Hz 21.7A 5000VA

Class I, IP34, ta:50°C

Standard: IEC 62109-1 Ed. 1.0 IEC 62109-2 Ed. 1.0

AS 62040.1.1:2003 AS/NZS 4777.2:2015

Conditions: Nil

Certification Mark: SAA181176 or RCM

Date First Registered: 3 May 2018
Date of Expiry: 3 May 2023

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au



www.jas-anz.org/register





Certificate of Suitability

Addendum

Certificate No.: SAA181176

Date of Issue: 3 May 2018

Class Description: Non-Declared Product Description: AC Battery System

General Modification:

Use of alternative trade name EGUANA.

Additional Models Description

ACB05-LB Battery cabinet for ACB05-LP.

ACB05-LE Battery expansion cabinet for ACB05-LP.

For and on Behalf of SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Sately Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to: www.saaapprovals.com.au



www.jas-anz.org/register



Issued: 03-05-18 181176/2a Correction to Description